

Current Transformer Cabinets

Gladstone Power and Light Area Units | UL listed



Underground Entry and Overhead Exit

Catalog Number	Amps	Voltage	Phase	SCCR	Dimensions			Cabinet Drawing	Bus Drawing
					H"	W"	D"		
GLAM-403	400	250	1Ø3W	65kA	42	24	8	20104-02	20104-809
GLAM-404	400	250	3Ø4W	65kA	42	24	8	20104-02	20104-809
GLAM-433	400	250	3Ø3W	65kA	42	24	8	20104-02	20104-809
GLAM-603	600	250	1Ø3W	65kA	42	24	8	20104-02	20104-811
GLAM-604	600	250	3Ø4W	65kA	42	24	8	20104-02	20104-811
GLAM-633	600	250	3Ø3W	65kA	42	24	8	20104-02	20104-883
GLAM-803	800	250	1Ø3W	65kA	42	24	8	20104-02	20104-821
GLAM-804	800	250	3Ø4W	65kA	42	24	8	20104-02	20104-821
GLAM-833	800	250	3Ø3W	65kA	42	24	8	20104-02	20104-887
GLAM-1204	1200	250	3Ø4W	85kA	48	46	12	20104-06	20104-834
GLAM-1233	1200	250	3Ø3W	85kA	48	46	12	20104-06	20104-764
GLAM-1604	1600	250	3Ø4W	85kA	66	54	14	20104-12	20104-856
GLAM-1633	1600	250	3Ø3W	85kA	66	54	14	20104-12	20104-765

Utility requirements for this equipment may vary. Always consult the serving utility for their requirements prior to ordering or installing this equipment. This product must be installed by a licensed electrician. Installation of this equipment may require local electrical inspector approval.



Current Transformer Cabinets

Gladstone Power and Light Area Units | UL listed

600 Volt, 3Ø-3W Units with provisions for mounting 2 potential transformers

Catalog Number	Amps	Voltage	Phase	SCCR	Dimensions			Cabinet Drawing	Bus Drawing
					H"	W"	D"		
GLAM-463	400	600	3Ø3W	65kA	48	36	14	20104-05	20104-761
GLAM-663	600	600	3Ø3W	65kA	48	36	14	20104-05	20104-762
GLAM-863	800	600	3Ø3W	65kA	48	36	14	20104-05	20104-763
GLAM-1263	1200	600	3Ø3W	85kA	48	46	12	20104-06	20104-764
GLAM-1663	1600	600	3Ø3W	85kA	66	54	14	20104-12	20104-765

600 Volt, 3Ø-4W Units with provisions for mounting 3 potential transformers

Catalog Number	Amps	Voltage	Phase	SCCR	Dimensions			Cabinet Drawing	Bus Drawing
					H"	W"	D"		
GLAM-464	400	600	3Ø4W	65kA	48	36	14	20104-05	20104-761
GLAM-664	600	600	3Ø4W	65kA	48	36	14	20104-05	20104-762
GLAM-864	800	600	3Ø4W	65kA	48	36	14	20104-05	20104-763
GLAM-1264	1200	600	3Ø4W	85kA	48	46	12	20104-06	20104-764
GLAM-1664	1600	600	3Ø4W	85kA	66	54	14	20104-12	20104-765

Utility requirements for this equipment may vary. Always consult the serving utility for their requirements prior to ordering or installing this equipment. This product must be installed by a licensed electrician. Installation of this equipment may require local electrical inspector approval.

