

# Meter Mounting Equipment

*Stainless Steel Products*



USS4701-O



UCSS3433

## Ringless | 200A | Single Position | 4,5 & 7 Terminal

Catalog Number	Service	Hub	# of Terms	Connectors CU/AL		Bypass	Dimensions		
				Line	Load		D"	W"	H'
USS3914-O	OH/UG	BLANK	4	#6-350 KCMIL	#6-350 KCMIL	None	4 <sup>7</sup> / <sub>8</sub>	13	19
USS4801-O	OH/UG	BLANK	4	#6-350 KCMIL	#6-350 KCMIL	Lever	4 <sup>7</sup> / <sub>8</sub>	13	19
USS4801-O-5T9	OH/UG	BLANK	5	#6-350 KCMIL	#6-350 KCMIL	None	4 <sup>7</sup> / <sub>8</sub>	13	19
USS4701-O	OH/UG	BLANK	7	#6-350 KCMIL	#6-350 KCMIL	Lever	4 <sup>7</sup> / <sub>8</sub>	13	19

## Ring Type | Provisions for Test Switch | Two piece front

Catalog Number	Service	Hub	# of Terms	Connectors CU/AL		Bypass	Dimensions		
				Line	Load		D"	W"	H'
UCSS3436-O	OH/UG	BLANK	6	#14 - #2	#14 - #2	Test Switch	5 <sup>1</sup> / <sub>8</sub>	12	20
UCSS3438-O	OH/UG	BLANK	8	#14 - #2	#14 - #2	Test Switch	5 <sup>1</sup> / <sub>8</sub>	12	20
UCSS3433-O	OH/UG	BLANK	13	#14 - #2	#14 - #2	Test Switch	5 <sup>1</sup> / <sub>8</sub>	12	20

## Notes

### FOR CONDUIT OPENING APPLICATIONS:

- All conduit openings have dimples provided to center location. Top conduit opening must have water-tight hub installed.
- \* Test switch provisions. Test switch not included.
- Consult factory for other units available in stainless steel

## MADE IN



AMERICA

Utility requirements for this equipment may vary. Always consult the serving utility for their requirements before ordering or installing equipment.

